

Dam Heightening Options in Switzerland to increase Hydro Storage Capacity and Winter Production

4 September 2019

Michelle Müller-Hagmann




SCCER-SoE Annual Conference 2019




Laboratory of Hydraulics, Hydrology and Glaciology

Dr. Michelle Müller-Hagmann | 1

Swiss Energy Strategy 2050 – Power supply and demand





Swiss Energy Strategy 2050 – Alternative power production



Increasing alternative power production → Growing need for power storage capacity

Electricity supply and demand



BFE, Schweizerische Elektrizitätsstatistik 2018

Dam heightening of Mauvoisin (1989 - 1991)



rhonefm.ch

Height H : 236.5 m → 250 m

$$\Delta H/H = 6\%$$

Volume V : 180 hm³ → 210 hm³

$$\Delta V/V = 17\%$$

Baublatt (1990)

Dr. Michelle Müller-Hagmann | 5



Laboratory of Hydraulics, Hydrology and Glaciology

Methodology

- (1) Establishing an evaluation matrix
- (2) Evaluation of 80 Swiss storage hydropower plants for
3 dam heightening options: $\Delta H/H = 5\%$ $\Delta H/H = 10\%$ $\Delta H/H = 20\%$
- (3) Selection of preferable heightening degree
- (4) Estimation of additional storage capacity and shifted electricity production (summer → winter)



Evaluation matrix for dam heightening

POWER GENERATION SYSTEM (46%)

(F) Hydrology (9%)

(G) Modification of hydraulic systems (9%)

(H) Electricity production (28%)

FUTURE RESERVOIR AREA (27%)

(A) Protected areas (9%)

(B) Land use and buildings (9%)

(C) Infrastructures (9%)


DAM (27%)

(D) Structural suitability (9%)

(E) Relative effort (18%)

0 - 4 points

(0 points = knock-out-criterion)



Evaluation – Case study Marmorera




Dam type: Earth core rockfill dam

Height: 91 m

Volume: 60 hm³

Energy head: 1070 m (Cascade)



ETH Zürich



Laboratory of Hydraulics, Hydrology and Glaciology


Marmorera – Evaluation: Future reservoir area (27%)

0 - 4 points (0 points = knock out criterion)

(A) Protected areas (9%)

- Reserves and areas of different protection degrees
- Designated wildlife area slightly affected

4 P.



(B) Land use and buildings (9%)

- Settlements, forests or agriculture land
- Restaurant affected

1 P.

(C) Infrastructures (9%)

- Embankments, traffic routes or supply and disposal lines
- important mountain pass road affected

1 P.



Marmorera – Evaluation: Dam (27%)

0 - 4 points (0 points = knock out criterion)

(D) Structural suitability (9%)

- Rock fill dams: $\Delta H/H \leq 5\%$ well-suited, $\Delta H/H \leq 10\%$ suitable, $\Delta H/H > 10\%$ less suitable

$\Delta H/H = 5\% \rightarrow$ 3 P.

$\Delta H/H = 10\% \rightarrow$ 2 P.

$\Delta H/H = 20\% \rightarrow$ 1 P.

(E) Relative effort (18%)

- Effort for dam and appurtenant structures, accessibility of construction sites
- No bottom and middle outlet modifications for heightening $\leq 10\%$
- Effort relative to additional storage capacity

$\Delta H/H = 5\% \rightarrow$ 2 P.

$\Delta H/H = 10\% \rightarrow$ 3 P.

$\Delta H/H = 20\% \rightarrow$ 3 P.



Marmorera – Evaluation: Power generation system (46%) (I/II)

0 - 4 points (0 points = knock out criterion)

(F) Hydrology (9%)

- Capacity-inflow-ratio (CIR): CIR < 1 → sufficient inflow for summer and winter production
- No additional adductions or pumps required → 4 P.

$\Delta H/H = 5\%$: CIR=0.33 → 4 P.

$\Delta H/H = 10\%$: CIR=0.36 → 4 P.

$\Delta H/H = 20\%$: CIR=0.43 → 4 P.

(G) Modification of hydraulic system (9%)

- Whole hydraulic system incl. linked reservoirs and upstream located power houses
- Assumption: Energy head rise ≤ 10%: slight modifications at electro-mechanical equipment
- Slight modifications at adduction and intermediate water intake
- Surge tank modifications increases with heightening degree

$\Delta H/H = 5\%$ → 3 P.

$\Delta H/H = 10\%$ → 3 P.

$\Delta H/H = 20\%$ → 2 P.



Marmorera – Evaluation: Power generation system (46%) (II/II)

0 - 4 points (0 points = knock out criterion)

(H) Electricity production (28%)

- Additional energy power production in winter semester
- Considering all power plants of cascades

0 - 50 GWh/a: 1 P. 50 - 100 GWh/a: 2 P. 100 - 200 GWh/a: 3 P. > 200 GWh/a: 4 P.

$\Delta H/H = 5\%: \approx 17 \text{ GWh/a} \rightarrow$ 1 P. $\Delta H/H = 10\%: \approx 32 \text{ GWh/a} \rightarrow$ 1 P. $\Delta H/H = 20\%: \approx 62 \text{ GWh/a} \rightarrow$ 2 P.

TOTAL SCORE OF MARMORERA:

$\Delta H/H = 5\% \rightarrow$ 23 / 44 P.

$\Delta H/H = 10\% \rightarrow$ 24 / 44 P.

$\Delta H/H = 20\% \rightarrow$ 25 / 44 P.

Preferable (?) heightening degree




Dam heightening – Potential

- 80 Dams evaluated, whereof 33 large dams ($V \geq 20 \text{ hm}^3$)

- 8 dams with knock out criteria

→ Additional winter production $\approx 2.3 \text{ TWh/a}$

(total energy equivalent of Swiss hydropower reservoirs: 8.8 TWh)




#	Name	Punkte	GWh
1	Lac des Dix +10%	39	546
2	Grimselsee +20%	35	233
3	Lac d'Emosson +10%	35	221
4	Oberaarsee +20%	34	154
5	Limmernsee +20%	33	125
6	Zervreilasee +5%	33	32
7	Lai di Curnera +20%	31	82
8	Mattmarksee +10%	30	68
9	Lac de Moiry +20%	29	167
10	Lago Ritom +10%	29	8
11	Lago di Lei +5%	28	101
12	Gigerwaldsee +5%	28	10
13	Klöntalersee +5%	28	5
14	Lago da l'Albigna +20%	28	73
15	Lago di Cavagnoli +10%	28	25
16	Lai da Sta. Maria +5%	27	30
17	Lai da Nalps +5%	27	19
18	Lago di Lucendro +5%	26	5
19	Lac de Cleuson +10%	26	16
20	Lac de l'Hongrin +20%	26	98
21	Lac des Toules +10%	26	19
22	Lago del Naret +20%	26	64
23	Lago del Sambuco +20%	25	96
24	Lai da Marmorera +20%	25	62
25	Lac de Salanfe +10%	24	48
26	Göscheneralpsee	0	-
27	Lac de Gruyère	0	-
28	Lac de Zeuzier	0	-
29	Lago di Vogorno	0	-
30	Räterichsbodensee	0	-
31	Schiffenensee +5%	0	-
32	Sihlsee +5%	0	-
33	Wägitalersee +5%	0	-

Dam heightening – Shifted energy production


Existing storage power plants: 21.1 TWh/a

Values of BFE (2018): average of 2009-2018




After 25 dam heightenings: 21.1 TWh/a

Shift from summer to winter: **2.3 TWh/a**



→ Winter deficit reduction ≈ 50% on average (data: 2009-2018)





BFE, Schweizerische Elektrizitätsstatistik 2018

Conclusions and Outlook

- Evaluation matrix
 - Suitable dams for heightening
 - Preferable heightening degrees
- Assessment of 80 dams in Switzerland
 - Heightening of 25 dams → 2.3 TWh additional winter production
 - Significantly higher independence of Swiss electricity supply
- Next step: analysis on feasibility of dam heightenings





Thank you for your attention

Dr. Michelle Müller-Hagmann
mueller-hagmann@vaw.baug.ethz.ch

Dr. David Felix
Dr. Helge Fuchs
Prof. Dr. Robert Boes
www.ethz.ch
www.vaw.ethz.ch

M. Baumann, A. Emmenegger, A. Kasper (2018)
J.C. Holland, S. Wolf, H. Zimmermann (2018)
C. Parravicini, D. Vicari, R. Werlen (2018)
A. Leimgruber (2018)